



TEST REPORT

High Voltage Ref. Lab.

Manufacturer: KASRA Co. Test item description: Insulation Sample Client:KASRA Co.

The issuing of this report does not mean a certificate for test object and is not according to the activities of "Assessment counsile and Accordance with Production Standards ".

Reference Laboratories Center

High Voltage Group

Address: End of Dadman Blvd., Shahrak-e-Ghods, P.O.Box: 14665/517 Tehran\ IRAN Tel: (+98-21) 8807 9400, Fax: (+98-21) 8807 8296 Email:<u>highvol@nri.ac.ir</u> Website:http://www.nri.ac.ir

High Voltage Ref. Lab.

Report Number: TH90079



	Insulation sample
	IEC 60243-1(1998)
	Compiled by: SAEED YEGANEH
	Approved by: SIAMAK ABYAZI
	Tests witnessed by:
	Date of issue:29.11.2011
	Testing Laboratory Name:
	Address
	Ghods, Tehran, Iran
	Tel/Fax: (+98-21)88079401-8/(+98-21) 88078296
	Web-site
	Test laboratory location: High voltage lab.
	Client's name KASRA Co.
	Request number: 822/7/90
	Request date: 15.10.2011
	Sample delivery data: 27.11.2011
	standard number: IEC 60243-1
	Test method Standard
	Non-standard test method:
	Report number: TH90079
	Sample number: STH90079
	Test item description:
	Manufacturer/ Client KASRA Co / KASRA Co
	Maladadea Contraction and Cont
	Serial number
	The test result related only to the sample tested.
	The copyright of this report is not validated without direct NRI HV Lab. approve.
	This report includes 5 pages
Tested	
	پژوهشکده انتقال و توزیع نیرو آزما بشگاه فشار قوی
	ازمانشگاه قسار قوی Page 2 of 5

The issuing of this report does not mean a certificate for test object and is not according to the activities of "Assessment counsel

and Accordance with Production Standards".

High Voltage Ref. Lab.

Report Number: TH90079



Contents

Title	Page	
1- Test object picture	4	
2- Technical specification of the test object assigned by the client	4	
3- Remarks	4	
4- Summary of test procedure and test Results	5	
4-1-Electerical Insulation sample		





Page 3of 5

High Voltage Ref. Lab. Report Number: TH90079



1- Test object picture





2- Technical specification of the test object assigned by the client

Thickness:	3.8mm
Thickness:	3.8mm

3- Remarks

Customer can complaint about test results up to one month after issue date of test report formally and in written. If any laboratory's fault is proven that affected the test result, performing of test will be done again without any payment. Samples are kept for six month in laboratory's archive. If customer wants to return the test samples, can't complaint to test results.

Sampling is performed by costumers itself and laboratory is not responsible for that.



Page 401 5

The issuing of this report does not mean a certificate for test object and is not according to the activities of "Assessment counsel

Report Number: TH90079



4- Summary of test procedure and test Results

Atmospheric Conditions in lab.						
Pressure:	P= 854.4hPa	Temperature:	t=14.9°C			
Humidity:	R=28.5%					

4.1- Electerical Insulation sample.

This test has been performed by a semiautomatic dielectric test set-type Dieltest DTS Produced by BAUR Company.

In this test a sample by the size of 5cm×5cm from the floor insulating is put inside a container full of transformer oil between two cylindrical brass electrodes with 6.4mm diameter.

Voltage increases to a breakdown (puncture) in the sample.

This test repeats for 4 other samples.

Sample code	Thichness(mm)	Increase rate of voltage (kV/s)	Breakdown voltage (kV)	Average breakdown voltage (kV)
STH90079	3.8	3	51.1-53.4-50.7-54.6-56.6	53.3



Page 5of 5